

LMS TECHNOLOGIES, INC.
6423 Cecilia Circle
Bloomington, MN 55439
Tel: (952) 918-9060, Fax: (952) 918-9061

Test Report - Ozone Output

Test Requested By: Airquality Technology (Shanghai) Co., Ltd
Manufacturer: Airquality Technology (Shanghai) Co., Ltd
Model Number: FAH
Dimensions: 61 cm x 37 cm x 15 cm
Filter Description: Micro Electrostatic Precipitator
Sample Obtained From: Airquality Technology (Shanghai) Co., Ltd

Test Date: 11/26/2018


LMS #: 5298

Test Conditions

Airflow Velocity: 2.5 m/s
Temperature: 22.0°C
Relative Humidity: 50.5%
Initial Resistance: 49.5 pascal @ 2.5 m/s
Gas Analyzer: ML 9810 Photometric Analyzer

Test Results

Total Test Time: 30 Minutes
Peak Ozone Concentration: 10 ppb
TWA Concentration: 5.6 ppb (30 Minute TWA)



CERTIFIED COPY
LMS TECHNOLOGIES, INC.

[Handwritten signature]