



LMS Technologies, Inc.

November 21, 2025

To Whom it may concern,

Under contract with AirQuality Technology (Shanghai) Co., Ltd., LMS Technologies measured ozone generation from unit FAH-G in a single-pass, ASHRAE 52.2 test duct for 10 minutes.

The testing result for ozone was 3.5 ppb.

Regards,
Al Vatine
President



CERTIFIED COPY
LMS TECHNOLOGIES, INC.



6423 Cecilia Circle, Bloomington, MN 55439

www.lmstechnologiesinc.com

Tel: (952) 918-9060

Fax: (952) 918-9061