



中国认可
国际互认
检测
TESTING
CNAS L1045

检 测 报 告

TEST REPORT

EET-2026AC-0041 (E)

产品名称: Electronic Air Filter
Name of Product

委托单位: AirQuality Technology (Shanghai) Co., Ltd.
Client

生产单位: AirQuality Technology (Shanghai) Co., Ltd.
Manufacture

检测类别: Entrusted
Test Category

建 科 环 能 检 测 有 限 公 司





建科环能科技有限公司
Jianke EET Co., Ltd.

No. of Report: EET-2026AC-0041 (E)

Page 1 of 3

Sample name	Electronic Air Filter	Sample No.	2026AC-0041
Client	AirQuality Technology(Shanghai)Co.,Ltd.	Test type	Entrusted
Manufacturer	AirQuality Technology(Shanghai)Co.,Ltd.	Brand	AIRQUALITY
Sample quantity	1	Type/Model	EAF
Test place	Fubi Road, Gequ, Tongzhou District, Beijing, China	Date of commission	2026-06-11
Serial No.	/	Date of test	2026-06-17~06-24
Sample Submission Date	2026-06-11	Production Date	/
Address	No.189, Fulianer Road, Baoshan District, Shanghai, China		
Test standard	GB/T 18204.5-2025<Examination methods for public places-Part 5: Central air conditioning and ventilation systems>		
Criteria based on	/		
Test item	Increase of TVOC Concentration		
Instruments	T-H11 Air Filter Test Device for Counting Method, T-H70 Steel Tape, T-IAQ143 GC-MS, T-IAQ59 Intelligent Four-way Atmospheric Sampler, T-IAQ60 Intelligent Four-way Atmospheric Sampler		
Test conclusion	Refer to page 2 for the detailed test result. 建科环能科技有限公司 检验检测专用章 Special Chapter for Inspection and Testing Report Date: 2026-06-26 1010210100691		
备注 Remark	/		

批准: 王明超
Approval

审核: 杨英霞
Verification

主检: 杨志远
Chief tester



建科环能科技有限公司
Jianke EET Co., Ltd.

No. of Report: EET-2026AC-0041 (E)

Page 2 of 3


Sample No.		2026AC-0041	
Test Velocity（m/s）		2.5	
Test Result			
No.	Test Item		Test Result
1	Increase of TVOC Concentration（mg/m ³ ）		No Increase
Note	1. The dimension of the outlet side is 257mm×527mm。		
	Below in this page is blank.		

技
专
006




Sample No.	2026AC-0041
Sample Description	
Voltage (V)	DC12-24
Dimension (mm)	287×592×95

Note: The photos of the sample are shown below.



Sample (Inlet side)



Sample (Outlet side)

Below in this page is blank.

